

REFERENTIES

- [1] R. Hasegawa, "Present status of amorphous soft magnetic alloys," *J. Magn. Magn. Mater.*, vol. 215–216, pp. 240–245, 2000.
- [2] R. Kolano, N. Wojcik, and W. Gawior, "A three-limb amorphous magnetic circuit for three-phase 200 kVA distribution transformers," *J. Magn. Magn. Mater.*, vol. 160, pp. 213–214, 1996.
- [3] S. Okamoto, M. Leki, N. Denis, K. Fujisaki and Y. Kato, "Core loss reduction of an interior permanent magnet synchronous amorphous stator core," *IEEE Transactions on Industry Applications*, vol. 52, no. 3, pp. 2261-2268, 2016.
- [4] K. Roman, K. Krysztof, K-B. Aleksandra, P. Marcin, S. Jan and Z. Przemyslaw. "Amorphous soft magnetic materials for the stator of a novel high-speed PMSM motor," *IEEE transactions on magnetics*, vol. 49, no. 4, pp. 1367-1371, 2012.
- [5] A. J. Moses, "Demonstration of the feasibility of the use of amorphous magnetic material as transformer core material," in *Proc. 12th Int. Conf. on Electricity Distribution*, Birmingham, 1993, pp.1-3.
- [6] Y. Okazaki, "Loss deterioration in amorphous cores for distribution transformers," *J. of Magnetism and Magnetic Materials*, vol. 160, pp. 217-222, 1996.
- [7] Metglas. "Amorphous alloys for transformer cores" 2011.
- [8] D. Eggers, S. Steentjes and K. Hameyer, "Advanced Iron-Loss Estimation for Nonlinear Material Behavior," *IEEE Transactions on Magnetics*, vol. 48, no. 11, pp.3021-3024, 2012.